

**GENERAL SPECIFICATIONS
GLASS OPERABLE PARTITIONS- GX SERIES
OMNIDIRECTIONAL PANELS
SECTION 10 22 26**

PART 1 – GENERAL

1.1 General description

- .1 Supply and install operable glass partitions. Provide all labor, materials, tools, equipment and services for glass operable partitions in accordance with provisions of contract documents.
- .2 Complete shop drawings are to be provided prior to fabrication indicating construction and installation details.

1.2 Quality assurance

- .1 Glass shall be tempered as per ASTM C1048-92.
- .2 Sound transmission coefficient: ASTM E90

1.3 Product delivery, storage and handling

- .1 Proper storage of partitions before installation and continued protection during and after installation will be the responsibility of the General Contractor.

1.4 Related work by others

- .1 Paint or otherwise finishing of all trims and other materials adjoining head and jamb of the partitions.
- .2 All headers, blockings, support structures, jambs, track enclosures, surrounding insulation, and sound baffles meeting quality assurance requirements.
- .3 Pre-punching of support structure in accordance with approved shop drawings.
- .4 Preparation of openings will be by General Contractor. Any deviation of site conditions contrary to approved shop drawings must be called to the attention of the architect.

1.5 Warranty

- .1 The operable partitions and installation shall be guaranteed for a period of no less than one (1) year and the track and trolley system for a period of no less than five (5) years against defects in materials and workmanship. This warranty covering material and labor shall be effective upon the date of signature of the certificate relative to the substantial completion of work.

PART 2 – PRODUCTS

2.1 Materials

- .1 Omnidirectional glass panels manually operated, **SERIES GX** as manufactured by Corflex.
 - .1 Panels shall be normally 93mm (3.66") thick, with concealed extruded aluminum frame, completely glazed on both sides. No exposed frame on all the partition surfaces.
 - .2 Panels shall be fully glass surfaced on both sides loaded with
 - a. 12mm laminated glass with a black silkscreen on the perimeter on each surface for panels
 - b. 10 mm laminated glass with a black silkscreen on the perimeter on each surface for doors
 - .3 The leading vertical edge of each panel shall incorporate a tongue with two vinyl gaskets to nest into the vertical recess in the edge of the adjoining panel creating a positive, interlocking joint that provides panel stability, ease of panel alignment and sound control.

Horizontal seals must not exceed the panel width to prevent damage while handling. Top and bottom horizontal seals shall be continuous contact, multi-layer, vinyl sweep seals. The top seals maintain contact with the track and the bottom seals maintain contact with the floor or other surface along the path of the movable wall.

2.2 Suspension system

- .1 Track shall be of clear anodized architectural grade extruded aluminum alloy 6063-T6. Track design shall provide integral support for adjoining ceiling, soffit, or plenum sound barrier. Track shall be connected to the structural support by pairs of 10 mm (3/8") diameter threaded steel hanger rods. L or T intersections shall be factory assembled and welded. Built-in ceiling trim shall be of anodized aluminum finish providing enclosure of plenum sound barrier on both sides of track for maximum sound control. A section of track will be removable in order to make it possible for a panel to be removed from

**GENERAL SPECIFICATIONS
GLASS OPERABLE PARTITIONS- GX SERIES
OMNIDIRECTIONAL PANELS
SECTION 10 22 26**

the track for later maintenance. Each panel shall be supported by two dual horizontal wheel type trolley assemblies. Only the last or before last panel will have a visible locking device installed in the bottom rail.

- .2 Each panel shall be supported by two-wheel counter-rotating horizontal carriers. Wheels to be of precision ground steel ball bearing with heat treated and hardened races encased with molded polymer tires. A report showing that a reliability test covering a distance of 160 kilometers was completed must be available on request.

2.3 Finishes

- .1 All aluminum components will have:

Choose:

- Black anodized finish
 Clear anodized finish
 Other color anodized finish

- .2 All vinyl and PJC trim will be

Choose:

- Black
 Grey
 Beige

2.4 Operation

- .1 The panels must be top supported and manually operated. Final partition closure to be by a full height hinged closure access panel at one end of the opening that hinges from a fixed two-piece telescopic aluminum jamb. The hinged panel shall be fitted with a lever type latch or lockset. A foot bolt will have to activate at the bottom of the panel next to the hinged closure panel. No screws will be visible on the jamb on either side when looking perpendicular to the panels when unstacked.

2.5 Acoustical performance

- .1 The panels must be designed to meet a performance of 50 STC.
- .2 Supply a copy of an acoustical test report certifying that the partition was tested with a performance of 50 STC by an independent accredited laboratory. The partition tested must be fully functional and meet ASTM-E90 standard. The test results must be similar to or exceed the performance specified. The acoustical test report must show the weight and the panel construction as well as the acoustical seals tested.
- .3 The panels shall weigh approximately 68 kg/m² (14 lbs/ft²).

PART 3 – EXECUTION AND INSTALLATION

3.1 Installation

- .1 Installation is to be completed by an authorized factory-trained installer.
- X If concrete anchoring
Concrete anchoring suspension and bracing must be done by the authorized factory-trained installer. Concrete anchors must meet seismic requirements (remove 1.4.3, pre-punching of support structure in accordance with approved shop drawings).